



Product Service

CERTIFICATE

No. B 078767 0002 Rev. 01

Holder of Certificate: **CHUNG KWANG ELECTRIC WIRE & CABLE CO., LTD.**

No. 33, Suey Tien Road, San Ho Li
Wuri Dist.,
414 Taichung City,
TAIWAN

Certification Mark:



Product:

Electric Cables

Electric cables for photovoltaic systems with a voltage rating of 1.5kV DC

Model(s):

**62930 IEC 131 1×2.5 mm², 1×4 mm², 1×6mm²
1×10 mm², 1×16 mm²**

Parameters:

Rated Voltage: DC 1500V (between conductors and between conductor and earth)
AC U₀/U: 1.0/1.0 kV
Class (IEC 61140): II
Ambient Temperature: -40°C ~+90°C
Max. Temperature at conductor: 120°C

Tested according to: IEC 62930(ed.1.0)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704071834201-01
Valid until: 2027-11-08

Date, 2022-11-09

(Yaqun Alex Liu)